



VARTA Storage GmbH  
Nürnberger Straße 64-65 - 86720 Nördlingen - Germany

## Compatibility List VARTA.wall

Version 1.5 (March 2025)

Inverter			Note
Manufacturer	Model series <i>Performance classes</i>	Firmware version	
 SMA	Sunny Tripower Smart Energy <i>5.0 / 6.0 / 8.0 / 10.0</i>	≥ 3.05	<i>From a technical point of view, there is no restriction on the expansion variants of the VARTA.wall for any of the inverter models listed above. All inverter models can be operated with 2-4 battery modules (10-20 kWh). However, please note the limitation of the maximum charging/discharging capacity when configuring the overall system.</i>
	Plenticore BI G2 <i>5.5 / 10.0</i>	≥ 2.13	
	Plenticore plus G2 <i>3.0 / 4.2 / 5.5 / 7.0 / 8.5 / 10.0</i>	≥ 2.13	
	Plenticore G3 <i>S / M / L</i>	≥ 3.04	
	Plenticore MP G3 <i>S / M</i>	≥ 3.04	
 Kostal			

### General information:

- The available date of the firmware versions that enable compatibility with the VARTA.wall depends on the respective release dates of the inverter manufacturers.
- Operation of the VARTA.wall is only permitted with the inverter models listed above. The use of a non-approved inverter model will invalidate the manufacturer's warranty granted by VARTA as well as product safety insurance.
- Before commissioning, make sure that the current firmware version of the VARTA.wall is installed.
- This document is subject to ongoing changes by VARTA and may not represent the current status. VARTA reserves the right to make changes.